




Application manual



KNX binary output module

EK-FA1-TP 4-channel

EK-FB1-TP 8-channel

Contents

1	Scope of the document.....	3
2	Product description	4
3	Switching, display and connection elements	5
4	Configuration	6
5	Commissioning	6
6	Function description.....	7
6.1	Offline operation.....	7
6.2	Online operation.....	7
6.2.1	Software working cycle	7
6.2.2	State variables (Communication objects)	7
6.2.3	Outputs.....	7
6.2.3.1	Output control features	8
6.2.3.2	Relay inversion.....	9
6.2.3.3	Feedback	9
6.2.3.4	Time delay.....	10
6.2.3.5	Staircase function.....	10
6.2.3.6	Logic function	14
6.2.3.7	Lock function	17
6.2.3.8	Forcing function.....	18
6.2.3.9	Scene management.....	19
6.2.3.10	Operating hours / Energy consumption counter	20
6.3	Device settings.....	21
6.3.1	Channels configuration	21
6.3.2	Channel x configuration	22
6.3.2.1	Main parameters	22
6.3.2.2	Staircase lighting function	26
6.3.2.3	Locking function	27
6.3.2.4	Logic function	28
6.3.2.5	Scenes function.....	29
6.3.2.6	Watts / Hours counter	30
7	Appendix.....	31
7.1	Communication objects table.....	31
7.2	Warning.....	33
7.3	Other information	33

1 Scope of the document

This application manual describes application details for the A1.0 release of the ekinex® KNX binary output modules EK-FA1-TP (4 channels) and EK-FB1-TP (8 channels).

The document is aimed at the system configurator as a description and reference of device features and application programming. For installation, mechanical and electrical details of the device please refer to the technical description datasheet.

Application manual and application programs for ETS are available for download at www.ekinex.com.

<i>Item</i>	<i>File name (## = release)</i>	<i>Version</i>	<i>Device rel.</i>	<i>Update</i>
Technical datasheet	STEKFA1TP_EN.pdf STEKFB1TP_EN.pdf	1.0	A1.0	02 / 2014
Application manual	MAEKFA1FB1TP_EN.pdf	1.1		07 / 2014
Application program	APEKFA1TP##.knxprod APEKFB1TP##.knxprod	1.0		02 / 2014

You can access the most up-to-date version of the full documentation for the device using following QR codes:

For the 4-channel interface EK-FA1-TP:



For the 8-channel interface EK-FB1-TP:



2 Product description

The ekinex® binary output modules EK-FA1-TP and EK-FB1-TP are S-mode KNX modular devices for independent switching respectively of 4 or 8 electrical loads; to this purpose, the outputs of the devices are equipped with potential-free relay contacts.

The two devices differ only for the number of the output channels; their operation is the same in every respect, except for the fact that, for the smaller unit, the parameters and communication objects bound to the upper 4 channels are not available. In this manual, both devices will be referenced interchangeably; only where differences exist, they will be explicitly highlighted.

The device is equipped with an integrated bus communication module and is designed for rail mounting in distribution boards.

For operation, the devices receives KNX telegrams from the bus, sent by another KNX device (such as a pushbutton, a sensor, a display, a timer, etc.); these telegrams cause the activation or deactivation of one or more relays.

Manual operation of an output channel is also possible by using the corresponding lever on the front side; the position of the lever simultaneously acts as an indicator of the switching status of the relay. Bistable relays ensure that the status of the outputs can be maintained even in case of failure of the bus voltage.

The device is powered by the KNX bus line with a 30 VDC SELV voltage and does not require auxiliary power; all required operation voltages for the input channels are produced inside the device. A reservoir capacitor is built in in order to supply the required power to the device while maintaining compliance to the KNX-prescribed bus power drain.



For further technical information, please also refer to the product datasheets STEKFA1TP_EN.pdf and STEKFB1TP_EN.pdf available on the ekinex website www.ekinex.com.

3 Switching, display and connection elements

The device is equipped with:

- a programming pushbutton and a programming LED
- switch levers for manual operation
- terminals for output load connection
- terminals for the KNX bus line connection




Fig. 1 - Switching, display and connection elements

4 Configuration

The exact functionality of the device depends on the software settings.

In order to configure and commission the device you need ETS4 or later releases and the proper ekinex[®] application program, either APEKFA1TP.knxprod or APEKFB1TP.knxprod, which can be downloaded from the ekinex[®] website www.ekinex.com.

The application program allows the configuration of all working parameters for the device.

The device-specific application program has to be loaded into ETS or, as alternative, the whole ekinex[®] product database can be loaded; at this point, all the instances of the selected device type can be added to the project.

For every single device, ETS allows to set the operating parameters individually for each input as described in detail in the following chapters.

The configuration can, and usually will, be performed completely offline; the actual transfer of the programmed configuration to the device takes place in the commissioning phase.

Product code	EAN	No. of channels	ETS application software (## = release)	Communication objects (max nr.)	Group addresses (max nr.)
EK-FA1-TP	8018417181139	4	APEKFA1TP##.knxprod	76	254
EK-FB1-TP	8018417181146	8	APEKFB1TP##.knxprod	152	254



Configuration and commissioning of KNX devices require specialized skills. To acquire these skills, you should attend training courses at a training center certified by KNX.

For further information: www.knx.org

5 Commissioning

After the device has been configured within the ETS project according to user requirements, the commissioning of the device requires the following activities:

- electrically connect the device, as described in the product datasheet, to the bus line on the final network or through a purposely setup network for programming;
- apply power to the bus;
- switch the device operation to programming mode by pressing the programming pushbutton located on the front side of the housing. In this mode of operation, the programming LED is turned on steady;
- upload the configuration (including the physical address) to the device with the ETS program.

At the end of the upload, the operation of the device automatically returns to normal mode; in this mode the programming LED is turned off. Now the device is programmed and ready for use on the bus.

6 Function description

After switching on the bus, which also acts as a power supply, the device becomes fully functional after a very short time needed for reinitialization. A further delay is programmable for the device to become active on the bus in order to avoid a bus traffic overload during the first moments of startup of the whole network.

In case of a bus power failure (voltage lower than 19 V for 1 s or more), the device becomes unreactive: the timing functions are not active, neither are the programmed group addresses.

As soon as the bus voltage is restored, the device will resume operation in its previous state (which is saved on power fail), unless different initialization settings are programmed.

6.1 Offline operation

A fully unprogrammed device causes no activity on the bus; it can be operated in manual mode by toggling the relay levers like a normal manual relay switch. Switching relay causes direct operation on output.

6.2 Online operation

The device is a switching endpoint, which activates its switch channels according to telegrams sent by other devices on the bus.

It also incorporates additional features such as e.g. timing and logic combination features, described in the following chapters.

6.2.1 Software working cycle

The software working cycle can be described as follows:

- Handle incoming telegrams from the KNX bus to update internal state variables
- Implement timing functions and other inbuilt functions to determine effect on physical outputs;
- Drive output relays outputs according to output status
- Respond to bus messages requesting feedback on the status of the outputs and of the device.

There are also special events on which it is possible to trigger additional features. These events are the bus failure and recovery, and the download of a new configuration with ETS.

6.2.2 State variables (Communication objects)

The determination of the status of physical outputs is made basing on internal state variables. These state variables, once assigned a group address, are actually KNX communication objects, which allows other devices on the bus to exploit the features of the device.

State variables undergo the usual rules for communication objects, among which – for instance – the effect of flags to determine how the change of value affects the transmission of the objects.

6.2.3 Outputs

The outputs are of binary type, i.e. they can only assume On and Off as values; each channel can be driven independently.

Each output has a relay with a single-pole, single-throw contact rated 10 A at 230 V AC. The state of the relays can be changed manually by operating the levers on the front of the device: beware though that

manual operation is not detected in any way by the internal circuitry, therefore the manual change of state does not affect the internal status of the device.

6.2.3.1 *Output control features*

In the most simple case there is only one communication object per channel, "On-Off command", that switches each channel output directly with a message.

By setting the device parameters, it is possible to activate additional features, most of which will also affect the outputs. These features are:

- Relay inversion: allows to short contacts on the Off logical value and disconnect on the On value.
- Feedback: sends message on each switching operation or cyclically each period of time
- Time delay block: allows to perform the actual relay switch with a programmable delay. It is available (with separate delay settings) both for the On-Off and for the Off-On transition.
- Staircase function: performs a retriggerable time period activation of an output.
- Logic function: allows to compute the output value as a logic function based on the value of several communication objects.
- Lock and Force: these functions can temporarily force the output to fixed values and also perform high priority switching operations.
- Scene management: - allows to save and recall a combination of state and values with a single telegram.
- Operating hours / Energy consumption counter: allows a limited tracking of energy consumption by accumulating "On" period durations over time.

The most significant functional blocks are described in the following scheme.




Fig. 2 - Functional blocks

6.2.3.2 Relay inversion

This feature inverts the status of the physical contact of a channel with respect to the exit status. Regardless of the “inversion” parameter setting, the following sections will always take “on” and “off” to be a reference to the logical status of the output, not the status of the relay contact switch.

6.2.3.3 Feedback

When feedback is enabled, a communication object corresponding to the status of the output is made available for reading by other devices on the bus. This object carries the actual state of the logic output, which is likely to be different from the command value because it includes the effect of all additional functions which may be active at the time.

If this communication object is defined, it is also transmitted on every state change, so it can be used to trigger events following the actual state change of an output; it is also possible to configure transmission at regular intervals.

Feedback telegrams are not sent if the relay levers are operated manually.

6.2.3.4 Time delay

The actual change of state of an output can be set to take place after a configurable delay from the change of the value of the corresponding communication object; this applies both to the on-off and the off-on transitions, each with its individually configurable delay value (T_{on} and T_{off} respectively).




Fig. 3 - Time delay

6.2.3.5 Staircase function

This function is intended to provide a simple and flexible way to manage the switching of staircase lights. These have following peculiar requirements:

- The light is activated by a “start” command (e.g. through a pushbutton or a presence sensor), and normally remain lit for a programmed time duration;
- There is a provision to enable a “stop” (Manual Off) command, again through a pushbutton or other events, that allows to switch the light off before the programmed time expires (e.g. because the person who triggered the presence sensor has surely left the building through an exit);
- There is a provision to allow another “start” command (Retriggering), received during activation, to restart the time duration counter;
- A further optional “pre-warning” function allows to briefly switch off the load a certain time before expiration (both times, i.e. pause duration and time before expiration, are configurable) in order to warn the user that the activation time is about to end.

Following pictures show the *Manual Off* feature:




Fig. 4 - Manual Off feature

Following pictures show the *Retrigger* feature:




Fig. 5 - Retrigger feature

Following pictures show the *Pre-warning* feature:




Fig. 6 - Pre-warning feature

6.2.3.6 Logic function

The device has a limited provision for the logic processing of internal variables in order to condition the status of outputs.

A given incoming output command can be used as an input to a logic block which operation is selectable between OR, AND and XOR (exclusive OR). Up to other 8 objects can be defined as additional inputs to the same block (each with an optional negation operation); these objects are directly accessible to other devices from the bus and they can be used as desired.

The input objects are logically combined as in following picture:




Fig. 7 - Logic functions

The logic combination block on the right works as follow according to which logical operation is selected:

- OR – the output is ON whenever any one of the inputs is ON;
- AND – the output is ON only if all of the inputs are ON;
- XOR – the output is ON if an ODD number of inputs are ON.

This latter operation is more intuitive when thinking of two inputs only: in this case, the output is ON when one input or the other is ON, but not both.

It must be noted that, in the above description, “input” and “output” are referred to the logical block; for the purpose of operation, the actual “inputs” are the logic objects, thus the optional inverters must be factored in.

This structure allows to implement fairly complex logical combinations; a more generic and powerful programming capability would add more complexity and therefore it would be far beyond the scope of an output module that is simple to use.

In the following pictures, the basic logic functions are illustrated, assuming the output command and one logic object are used:




Fig. 8 - Logic OR function




Fig. 9 - Logic AND function




Fig. 10 - Logic XOR function

6.2.3.7 Lock function

If the locking feature is enabled, the operation of a channel can be inhibited by writing a value in a communication object. The value written is of the KNX type “enable”; please beware that the meaning of this value is “*activate lock*”, which is not to be confused either with “enable *locking function*” or with “enable output”. The meaning of the value can be optionally inverted through a configuration parameter (an “enable on” value can be interpreted as “lock off”).

A locked output ignores the switching commands that are received for the duration of the lock, thereby maintaining the status it has upon lock entry. The status of the output can be set to a particular value both when the lock is set and when it is released; it is also possible to determine whether the lock status should be maintained or changed on recovery after a bus power-off.




Fig. 11 - Lock function

6.2.3.8 Forcing function

The forced control is very similar to the basic direct command of the output value, but with the peculiarity that it overrides both the “regular” set value and every other value conditioning feature (i.e. logic function, staircase timing etc.).

It is possible to set what value the output should assume both when the output forcing is released and also on recovery after a bus power-off if forcing was previously in effect.




Fig. 12 - Forcing function

The “Force” command has priority over Locking (which acts on the ordinary on-off command); therefore, a locked output can still be operated through “Force” commands.

The KNX command code for the “Force” operation is a 2 bit value; the *priority* bit determines whether the output value must be forced, in which case the *value* bit is assigned to the output.

In the figure above, NP means that the *priority* bit is 0 (No Priority), while the PON and POFF codes indicate the values with *priority* = 1 and *value* respectively 1 or 0.




Fig. 13 - Force command bits

6.2.3.9 Scene management

Each output can be linked to up to 8 scene codes; when one of these scene codes is recalled through a bus command originated by any controller device, the output will assume a preset value. An additional delay can be defined for the output activation (or deactivation) from the moment the scene code is recalled.

The output value for a scene can either be fixed and chosen in the configuration phase, or it can be defined as reprogrammable through a Scene Learning command.

If this latter option is enabled (for each single output), whenever a Scene Learning command is received on the bus for a specific scene code to which the output has an association, the device will store the current output status value for that scene. This value will then be recalled in subsequent scene activations.




Fig. 14 - Scene store / recall command code

6.2.3.10 Operating hours / Energy consumption counter

For each output, an activation counter can be associated which accumulates the count of hours that the output passed in the “on” state. In terms of communication objects, this counter has the format of a KNX hour counter, thus it also has a “reset” command and a “runout” alarm in case the maximum value is overflowed.

An additional parameter allows to define a conventional electrical power which is associated to the load; although this is not a “real” power metering, but merely a conversion factor between activation time and the estimated consumed power, nonetheless it can supply a useful indication for approximate power monitoring, particularly for resistive or fixed-power loads like lights or many other home or office appliances .

The power counter also has an associated KNX “kWh counter” communication object with its own reset command.




Fig. 15 – Operating hours and Energy counter

6.3 Device settings

This section lists all configurable parameters and describes related communication objects.

Every channel offers the same set of communication objects and parameters, but they may all be independently configured.

Hereafter, a generic channel number is referenced as “x” (where x = 1...8).



The parameter values highlighted in bold represent the default value.

The device settings are divided in two main groups: the general channel configuration settings and the channel-specific settings.

6.3.1 Channels configuration

These settings configure which channels of the device are activated.

Activating a channel causes the creation of a main switching communication object which is the minimal functionality to switch an output relay through a bus telegram.

For outputs 2 and above, instead of being explicitly defined, the channel configuration can be copied from any of the preceding channels. If this option is selected, the corresponding channel can be made to perform the exact same kind of function as the source channel.

This allows to spare time in configuring the device, at the same time assuring that there is no inconsistency between two channels that are meant to be configured in exactly the same way.

It must be noted that to copy the configuration from another channel is just a shortcut for the selection of configuration options; it is in no way implied that the two channels share any of the involved communication objects. If the configuration of the original channel is varied, then so is the “derived” channel; in the same fashion, if the original channel is disabled, so is also the derived one.

Parameter name	Conditions	Settings
Output x	-	disabled enabled copy parameters from channel*
<i>Enable output Channel x.</i> <i>* This option is only available for channels nr. 2 and above.</i>		
Output x – Copy from channel	Output x = copy parameters from channel	1...(x-1)

Object name	Conditions	Size	Flags	DPT	CO number(s)
Channel X – On/off Command	Channel x = enabled	1 bit	CRWTU	[1.001] on/off	0, 19, 38, 57, 76, 95, 114, 133
<i>This communication object is the standard “handle” for switching the output through a bus command.</i>					

6.3.2 Channel x configuration

6.3.2.1 Main parameters

In this section most of the configurable parameters for the output are listed.

Parameter name	Conditions	Settings
Relay operation	-	not inverted inverted
	<i>In the "not inverted" mode, the relay contacts (i.e. the physical output terminals) are shorted when the output is On (active).</i>	
Behaviour at bus off	-	off on no change
	<i>Allows to determine the state of the output when a bus voltage failure is detected; the output is switched, using the local power reserve, before the device goes offline.</i>	
Behaviour at bus on	-	off on no change previous state
	<i>Allows to determine the state of the output after bus recovery. The "previous state" option allows to undo any output change effected by manually operating the relay levers.</i>	
Behaviour after download	-	off on no change
	<i>Allows to determine the state of the output when the device resumes operation after a new parametrization has been downloaded.</i>	
Status feedback telegram	-	enabled / disabled
	<i>Enables or disables the output change notification through a bus telegram. No telegrams are sent after manual operations through the lever switches on the front side. Updating the object from "ON" to "ON" or from "OFF" to "OFF" has no influence on the switching status feedback.</i>	
Status feedback telegram – Delay after bus voltage recovery	Status feedback telegram = enabled	hh:mm:ss.fff (00:00:03.000)
	<i>Time after bus voltage recovery before status feedback telegrams begin to be sent. The delay has no effect on the behaviour of the outputs; only the feedback telegrams are delayed. The outputs can therefore be activated during the delay after a bus voltage recovery. During this delay, no feedback telegram will be transmitted even if a switching occurs; the feedback telegram for a switch during the delay period is lost.</i>	

Parameter name	Conditions	Settings
Status feedback telegram – Transmission cycle time	Status feedback telegram = enabled	hh:mm:ss (00:00:00)
	Interval between cyclical transmissions. A zero value (00:00:00) means no cyclical transmission (feedback telegrams are only sent on value change). Values less than "00:00:10" (ten seconds) are considered by the firmware in any case as 10 (ten) seconds; the maximum value is 18:12:15.	
On delay time	-	hh:mm:ss.fff (00:00:00.000)
	Delay between the "On" command telegram and the actual output activation. This time delay does not affect the output of the staircase and forced control functions. For the scene function the delay can be set separately. Updating the object from "ON" to "ON" or from "OFF" to "OFF" retrigger the delay time.	
Off delay time	-	hh:mm:ss.fff (00:00:00.000)
	Delay between the "Off" command telegram and the actual output deactivation. Same comments as for the "On delay time" parameter apply.	
Staircase lighting function	-	enabled / disabled
	Enables or disables the staircase lighting feature. For further details and parameter descriptions see the corresponding section below.	
Locking function	-	enabled / disabled
	Enables or disables the capability of locking the input through a remote command. For further details and parameter descriptions see the corresponding section below.	
Forcing function	-	enabled / disabled
	Enables or disables the capability of forcing the input through a remote command. For further details and parameter descriptions see the corresponding section below.	
Forcing function - Behaviour end forced control	Forcing function = enabled	off on no change previous value
	Allows to determine the state of the output when the forcing is released.	
Forcing function - Behaviour after bus recovery	Forcing function = enabled	off on no change previous value
	Allows to determine the state of the output when the device resumes operation after bus voltage recovery. After bus voltage recovery, forcing is implicitly released, and the output value is set according to this setting.	
Logic function	-	enabled / disabled
	Enables or disables the Logic input conditioning feature. For further details and parameter descriptions see the corresponding section below.	

Parameter name	Conditions	Settings
Scenes function	-	enabled / disabled
<i>Enables or disables the Scene function. For further details and parameter descriptions see the corresponding section below.</i>		
Operating hours / energy counter	-	enabled / disabled
<i>Enables or disables the Hour / Energy counter function. For further details and parameter descriptions see the corresponding section below.</i>		

Object name	Conditions	Size	Flags	DPT	CO number(s)
Channel x – On/off status	Status feedback telegram = enabled	1 bit	CR - T -	[1.001] switch	1, 20, 39, 58, 77, 96, 115, 134
<i>Sent at any change of the output state and also periodically, as configured. No telegrams are sent for manual operations of the relay lever switches.</i>					
Channel x – Staircase lighting start stop command	Staircase lighting function = enabled	1 bit	C - W - -	[1.001] on/off	2, 21, 40, 59, 78, 97, 116, 135
<i>Starts the staircase light timing with an On value. The timed activation automatically stops at the end of the preset time. If "Manual off" is enabled, the communication object will stop the timing with an Off value.</i>					
Channel x – Lock command	Locking function = enabled	1 bit	C - W - -	[1.003] enable	3, 22, 41, 60, 79, 98, 117, 136
<i>Inhibits the switching commands for the output when an "enable" telegram is received, and unlocks them when a "disable" telegram is received.</i>					
Channel x – Forcing command	Forcing function = enabled	2 bit	C - W - -	[2.001] switch control	4, 23, 42, 61, 80, 99, 118, 137
<i>Allows to force the status of an output. It is composed of 2 bits: the first one is used for the priority value (i.e. defines whether the forcing is in effect, "Priority", or not) and the second one for the imposed value (which is not considered if forcing is not effective).</i> 2 bit Bit number 10 0 = off, 1 = on 0 = No priority, 1 = Priority					

Object name	Conditions	Size	Flags	DPT	CO number(s)								
Channel x – Scene number	Scene function = enabled	1 Byte	C - W - -	[17.001] scene number [18.001] scene control	13, 32, 51, 70, 89, 108, 127, 146								
Allows to recall a scene setting for the status of the output, and to store current status in association to the specified scene. 1 Byte Bit number <table><tr><td>7</td><td>6</td><td>5</td><td>4</td><td>3</td><td>2</td><td>1</td><td>0</td></tr></table> scene number (1-64) not used 0 = recall, 1 = save						7	6	5	4	3	2	1	0
7	6	5	4	3	2	1	0						
Channel x – kWh counter	Operating hours / energy counter = enabled	4-byte signed counter	CR - T -	[13.013] active energy [kWh]	14, 33, 52, 71, 90, 109, 128, 147								
Stores the current counter value of the accumulated energy.													
Channel x – kWh counter reset command	Operating hours / energy counter = enabled	1 bit	C - W - -	[1.015] reset	15, 34, 53, 72, 91, 110, 129, 148								
Resets the energy counter to 0.													
Channel x – Hours counter	Operating hours / energy counter = enabled	2-byte unsigned counter	CR - T -	[7.007] time [h]	16, 35, 54, 73, 92, 111, 130, 149								
Stores the current counter value of the accumulated operating time.													
Channel x – Hours counter reset command	Operating hours / energy counter = enabled	1 bit	C - W - -	[1.015] reset	17, 36, 55, 74, 93, 112, 131, 150								
Resets the operating hour counter to 0.													
Channel x – Hours counter runout	Operating hours / energy counter = enabled	1 bit	CR - T -	[1.005] alarm	18, 37, 56, 75, 94, 113, 132, 151								
1-bit alarm sent when the time counter reaches the maximum value of 65535 hours.													

6.3.2.2 Staircase lighting function

Parameter name	Conditions	Settings
Staircase lighting time	Staircase lighting function = enabled	hh:mm:ss (00:01:00)
	<i>Duration of staircase lighting time.</i> <i>This time is the one shown on the time diagram in the descriptive section of this manual as "T_s".</i>	
Manual off	Staircase lighting function = enabled	enabled / disabled
	<i>When enabled, it allows an "Off" command to terminate the lighting time.</i> <i>The "Off" command can be sent at any time with the same effect, including when the pre-warning is activated.</i>	
Retriggerable	Staircase lighting function = enabled	enabled / disabled
	<i>When enabled, it allows a new "On" command to restart the timing.</i> <i>The "On" command can be sent at any time with the same effect, including when the pre-warning is activated.</i>	
Pre-warning	Staircase lighting function = enabled	enabled / disabled
	<i>Activates the pre-warning feature.</i> <i>For a detailed description see the corresponding section of this manual.</i>	
Pre-warning – Pre-warning time	Staircase lighting function = enabled Pre-warning = enabled	hh:mm:ss (00:00:10)
	<i>Specifies how much time before the end of the timing a pre-warning light interruption will be carried out.</i> <i>The time interval specified includes the interruption time.</i> <i>The maximum value is 18:12:15.</i> <i>This time is the one shown on the time diagram in the descriptive section of this manual as "T_{p-w}".</i>	
Pre-warning – Interruption time	Staircase lighting function = enabled Pre-warning = enabled	hh:mm:ss.fff (00:00:00.500)
	<i>Specifies the duration of the pre-warning interruption.</i> <i>This time is the one shown on the time diagram in the descriptive section of this manual as "T_i".</i>	



- The pre-warning time should be shorter than the staircase time ($T_{P-W} < T_S$) and the interruption time shorter than the pre-warning time ($T_I < T_{P-W}$).
- Time delays have no influence on the staircase function (if enabled).
- A staircase timing in progress will be terminated by a reset of the actuator (bus voltage recovery or ETS reprogramming) or by using any function that affects the output (i.e. normal switching, forced control, logic function, scene recall), even if the function does not cause an actual change in the output value.
On a forced termination, the value of the output remains unchanged; the same that is true also if the termination occurs during pre-warning time.

6.3.2.3 Locking function

Parameter name	Conditions	Settings
Lock device signal	Locking function = enabled	not inverted / inverted
	<i>Allows to interpret a "lock activate" telegram as unlock and vice-versa.</i>	
After bus recovery	Locking function = enabled	unlock lock previous state
	<i>Defines how to set the lock status after bus voltage recovery.</i>	
Behaviour at locking	Locking function = enabled	off on no change
	<i>Defines how to set the output value when entering the lock state. Please notice that this behaviour refers to an explicit activation of the lock state through a KNX command; restoring the lock state following internal operation, like e.g. after bus recovery, does not count as a positive activation.</i>	
Behaviour at unlocking	Locking function = enabled	off on no change updated value value before locking
	<i>Defines how to set the output value when the lock is deactivated. Updated value is the latest one that the output would assume if it had not been locked, i.e. it includes the output value change generated by whatever other function in the meantime. Value before locking is the value that the output had before the lock was activated.</i>	

6.3.2.4 Logic function

Parameter name	Conditions	Settings
Logic operation type	Logic function = enabled	OR AND XOR
<i>Defines the logic operation to perform on allowable inputs.</i>		
Read delay after bus recovery	Logic function = enabled	hh:mm:ss.fff (00:00:10.000)
<i>After a bus voltage recovery, the device waits for the specified time before validating the logic objects used as inputs; a request is sent for each logical object value which has not arrived within the read delay. The maximum value is 00:10:55.350.</i>		
Logic object <i>n</i>	Logic function = enabled	disabled / enabled
<i>Defines which logic object is used as input. Disabled logic objects are completely ignored and corresponding communication objects do not appear.</i>		
Logic object <i>n</i> – Logic object <i>n</i> negated	Logic function = enabled Logic object <i>n</i> = enabled	no / yes
<i>Applies a logical negation to the value of the input object.</i>		



The logic function is carried out only if and when at least one of the enabled input objects is updated by a bus telegram.

Object name	Conditions	Size	Flags	DPT	CO number(s)
Channel <i>x</i> – Logic Object <i>n</i>	Logic function = enabled Logic object <i>n</i> = enabled	1 bit	CRWTU	[1.*] <i>generic 1-bit</i>	Ch. 1: 5...12 Ch. 2: 24...31 Ch. 3: 43...50 Ch. 4: 62...69 Ch. 5: 81...88 Ch. 6: 100...107 Ch. 7: 119...126 Ch. 8: 138...145
<i>For each channel, the CO numbers corresponding to logic objects 1 to 8 are listed.</i>					

6.3.2.5 Scenes function

Parameter name	Conditions	Settings
Download overwrites learned behavior	Scenes function = enabled	no / yes
	<i>Defines whether the download of a program on the device should erase and overwrite the stored scene output values previously learned and stored in the device. When the device is put into operation for the first time, this parameter should be set to "yes" (default value) so that the output is initialized with valid scene values. Otherwise, the values are set to "0" (off) for all scenes.</i>	
Scene <i>n</i>	Scenes function = enabled	enabled / disabled
	<i>Enables or disables a new scene code to be assigned to the output.</i>	
Scene <i>n</i> – Scene number	Scenes function = enabled Scene <i>n</i> = enabled	1...64 (1)
	<i>Scene number to be assigned to the output. The output will respond to scene commands that match the specified number.</i>	
Scene <i>n</i> – Output behavior	Scenes function = enabled Scene <i>n</i> = enabled	off / on
	<i>(Initial) output value for the selected scene. This value will be possibly overwritten by a scene "store" command if the "Learning mode" option is enabled.</i>	
Scene <i>n</i> – Activation delay	Scenes function = enabled Scene <i>n</i> = enabled	hh:mm:ss.ff (00:00:00.00)
	<i>Delay between a scene "recall" command and the actual output switching. The maximum value is 01:49:13.50.</i>	
Scene <i>n</i> – Learning mode	Scenes function = enabled Scene <i>n</i> = enabled	disabled / enabled
	<i>When disabled, the scene "store" commands are ignored and only the output values set in the configuration are used.</i>	



- Each scene recall telegram restarts the activation delay.
- If a new scene recall telegram is received while a delay is active (scene recall not yet executed), the old - and not yet recalled - scene will be rejected and the newest scene value will be in effect.
- The scene recall delay has no influence on the saving of scene values when the learning mode is active.
- If the same scene number is set for several scene entries, only the scene with the lowest entry number (1...8) will be considered. The other internal scenes will be ignored in this case.
- The scene recall can be overridden by a *forced control* or a *lock* function.

6.3.2.6 Watts / Hours counter

Parameter name	Conditions	Settings
Output load [W]	Operating hours / energy counter = enabled	-671088640...+670760960 (1000)
	Defines the nominal rated power to be considered in computing the accumulated power consumption for the load connected to this output. The total energy consumed [kWh] is calculated as the product of the specified value [W] and the operating hours [h].	
Consumption / hours cyclic sending	Operating hours / energy counter = enabled	hh:mm:ss (00:00:00)
	Defines the time interval for the cyclic retransmission of the counter values (both for accumulated time and energy). Please notice that, in order for any of these values to be transmitted, the corresponding object must obviously have a group address assigned. A value of zero (00:00:00) disables cyclic transmission.	



- Note that manual activation of the lever switches on the front of the device does not affect the counter.
- During ETS programming or bus voltage failure, even if the output is in the “On” position, the counter stops counting.

7 Appendix

7.1 Communication objects table

Following is a summary of all KNX Communication Objects (CO) and corresponding Data Point Types (DPT) defined by the application program according to configuration options.

The listing order is generally by CO number.

Object name	Conditions	Size	Flags	DPT	CO number(s)
Channel X – On/off Command	Channel x = enabled	1 bit	CRWTU	[1.001] on/off	0, 19, 38, 57, 76, 95, 114, 133
This communication object is the standard “handle” for switching the output through a bus command.					
Channel x – On/off status	Status feedback telegram = enabled	1 bit	CR - T -	[1.001] switch	1, 20, 39, 58, 77, 96, 115, 134
Sent at any change of the output state and also periodically, as configured. No telegrams are sent for manual operations of the relay lever switches.					
Channel x – Staircase lighting start stop command	Staircase lighting function = enabled	1 bit	C - W - -	[1.001] on/off	2, 21, 40, 59, 78, 97, 116, 135
Starts the staircase light timing with an On value. The timed activation automatically stops at the end of the preset time. If “Manual off” is enabled, the communication object will stop the timing with an Off value.					
Channel x – Lock command	Locking function = enabled	1 bit	C - W - -	[1.003] enable	3, 22, 41, 60, 79, 98, 117, 136
Inhibits the switching commands for the output when an “enable” telegram is received, and unlocks them when a “disable” telegram is received.					
Channel x – Forcing command	Forcing function = enabled	2 bit	C - W - -	[2.001] switch control	4, 23, 42, 61, 80, 99, 118, 137
Allows to force the status of an output. It is composed of 2 bits: the first one is used for the priority value (i.e. defines whether the forcing is in effect, “Priority”, or not) and the second one for the imposed value (which is not considered if forcing is not effective). 2 bit Bit number 1 0 0 = off, 1 = on 0 = No priority, 1 = Priority					

Object name	Conditions	Size	Flags	DPT	CO number(s)								
Channel x – Logic Object <i>n</i>	Logic function = enabled Logic object <i>n</i> = enabled	1 bit	CRWTU	[1.*] <i>generic 1-bit</i>	Ch. 1: 5...12 Ch. 2: 24...31 Ch. 3: 43...50 Ch. 4: 62...69 Ch. 5: 81...88 Ch. 6: 100...107 Ch. 7: 119...126 Ch. 8: 138...145								
For each channel, the listed CO numbers corresponding to logic objects 1 to 8 are listed.													
Channel x – Scene number	Locking function = enabled	1 Byte	C-W - -	[17.001] scene number [18.001] scene control	13, 32, 51, 70, 89, 108, 127, 146								
Allows to recall a scene setting for the status of the output, and to store current status in association to the specified scene. 1 Byte Bit number <table><tr><td>7</td><td>6</td><td>5</td><td>4</td><td>3</td><td>2</td><td>1</td><td>0</td></tr></table> scene number (1-64) not used 0 = recall, 1 = save						7	6	5	4	3	2	1	0
7	6	5	4	3	2	1	0						
Channel x – kWh counter	Operating hours / energy counter = enabled	4-byte signed counter	CR-T -	[13.013] active energy [kWh]	14, 33, 52, 71, 90, 109, 128, 147								
Stores the current counter value of the accumulated energy.													
Channel x – kWh counter reset command	Operating hours / energy counter = enabled	1 bit	C-W - -	[1.015] reset	15, 34, 53, 72, 91, 110, 129, 148								
Resets the energy counter to 0.													
Channel x – Hours counter	Operating hours / energy counter = enabled	2-byte unsigned counter	CR-T -	[7.007] time [h]	16, 35, 54, 73, 92, 111, 130, 149								
Stores the current counter value of the accumulated operating time.													
Channel x – Hours counter reset command	Operating hours / energy counter = enabled	1 bit	C-W - -	[1.015] reset	17, 36, 55, 74, 93, 112, 131, 150								
Resets the operating hour counter to 0.													
Channel x – Hours counter runout	Operating hours / energy counter = enabled	1 bit	CR-T -	[1.005] alarm	18, 37, 56, 75, 94, 113, 132, 151								
1-bit alarm sent when the time counter reaches the maximum value of 65535 hours.													

7.2 Warning

- Installation, electrical connection, configuration and commissioning of the device can only be carried out by qualified personnel
- Opening the housing of the device causes the immediate end of the warranty period
- ekinex[®] KNX defective devices must be returned to the manufacturer at the following address: SBS S.p.A. Via Circonvallazione s / n, I-28010 Miasino (NO) Italy

7.3 Other information

- This application manual is aimed at installers, system integrators and planners
- For further information on the product, please contact the ekinex[®] technical support at the e-mail address: support@ekinex.com or visit the website www.ekinex.com
- ekinex[®] is a registered trademark of SBS S.p.A.
- KNX[®] and ETS[®] are registered trademarks of KNX Association cvba, Brussels

© SBS S.p.A. 2014. The company reserves the right to make changes to this documentation without notice.